

CERTIFICATE OF COMPLIANCE

Certificate Number 20160331-EX454
Report Reference EX454-20160330
Issue Date 2016-MARCH-31

Issued to: RELIABLE AUTOMATIC SPRINKLER CO INC
1470 SMITH GROVE RD
LIBERTY SC 29657

**This is to certify that
representative samples of**

SPRINKLERS, AUTOMATIC AND OPEN
Automatic dry type sprinklers with a maximum length of 36
in., SIN RA5532, 1 in. NPT, K = 8.0 concealed horizontal
sidewall extended coverage light hazard, glass bulb type
heat responsive element.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 199, Automatic Sprinklers for Fire-Protection Service
ULC/ORD-C199-03, Automatic Sprinklers For Fire-
Protection Service

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

