

Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
R1015	5.6	Pendent	SR	Fusible	1/2	Brass, Chrome, Black Plated, Bright Brass, Zinc Plated	135, 165, 212, 286 (57, 74, 100, 141)
R1015	5.6	Recessed Pendent	SR	Fusible	1/2	Brass, Chrome, Black Plated, Bright Brass, Zinc Plated	135, 165, 212 (57, 74, 100)

Prepared for:

The Reliable Automatic Sprinkler Co., Inc.
1470 Smith Grove Road, Liberty, SC 29657, USA

Manufacturing Location:

The Reliable Automatic Sprinkler Co., Inc.
1470 Smith Grove Road, Liberty, SC 29657, USA

FM Approvals Class: 2015, 2017

FM Approval Standard: Class Number 2000 (November 2024)

Approval Identification: PR463193

Approval Granted: 3 February 2025

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



A handwritten signature in black ink, appearing to read 'D. B. Fuller'.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
One Technology Way
Norwood, MA 02062 USA

