CERTIFICATE OF COMPLIANCE

Certificate Number

EX744

Report Reference

EX744-19720121

Date

2021-September-15

Issued to:

RELIABLE AUTOMATIC SPRINKLER CO INC

1470 Smith Grove Rd Liberty SC, 29657 US

This is to certify that

VALVES, ALARM

representative samples of

See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the

Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 193 - Standard for Alarm Valves for Fire-Protection

Service

ULC/ORD-C193-1975 - Standard for Alarm Valves for Fire-

Protection Service

Additional Information:

See the UL Online Certifications Directory at

https://ig.ulprospector.com for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.





CERTIFICATE OF COMPLIANCE

Certificate Number

EX744

Report Reference

EX744-19720121

Date

2021-September-15

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Alarm Valves:

Model E, rated 175 psig, 65 mm, 2-1/2, 3, 4, 6, and 8 in. sizes for vertical and horizontal installation.

Model E, rated 175 psig, 4, 6 and 8 in. sizes for horizontal or vertical installation for use with the E-3 compact trim assembly.

Model E-3, rated 300 psig,2-1/2, 3, 4, 6 and 8 in. sizes for horizontal or vertical installation for use with the E-3 compact trim assembly.

Model "E-1" retarding chamber with Model A or B strainer and with Model C water motor and gong (see Vol. 2).

Model "S-1" retarding chamber for use with Model E-3 Valve



