

CERTIFICATE OF COMPLIANCE

Certificate Number 20180420-EX3160
Report Reference EX3160-20121114
Issue Date 2018-APRIL-20

Issued to: RELIABLE AUTOMATIC SPRINKLER CO. INC.
1470 Smith Grove Rd.
Liberty, SC 29657
USA

This is to certify that representative samples of CheckValves
REL-FCV-50FF,REL-FCV-L501F

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 312 & ULC/ORD-C312, Check Valves for Fire Protection Service

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20180420-EX3160
Report Reference EX3160-20121114
Issue Date 2018-APRIL-20

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Swing-type check valve, Model REL-FCV-50FF, sizes 2, 2-1/2, 3, 4, 5, 6, 8, 10 and 12 NPS with rubber faced checks, rated for 300 psi, horizontal or vertical installation.

Swing type, horizontal or vertical installation, Model(s) REL-FCV-L501F, size 2, 2-1/2, 3, 4, 5, 6, 8, 10 or 12 NPS with rubber faced checks, rated for 300 psig



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

